



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 31525-99

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**Soprema, Inc.**  
**310 Quadral Drive**  
**Wadsworth, OH 44281**

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### **DESCRIPTION: Soprema Self-Adhered Modified Bitumen Roofing Systems over Cementitious Wood Fiber Decks.**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 14.

The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 13-0205.02**  
**Expiration Date: 12/31/14**  
**Approval Date: 08/01/13**  
**Page 1 of 14**

## ROOFING SYSTEM APPROVAL

Category: Roofing  
Sub-Category: Modified Bitumen  
Material: SBS  
Deck Type: Cementitious Wood Fiber  
Maximum Design Pressure: -60 psf.

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Soprabase	39" x 99' (3 sq.)	ASTM D4601	Oxidized asphalt, polyester reinforced, sand-surfaced base sheet. <b>For use as a base/ply sheet only.</b>
Soprabase S	39" x 65' (2 sq.)	ASTM D4601	SBS modified bitumen, polyester reinforced, sand-surfaced base sheet. <b>For use as a base/ply sheet only.</b>
Colvent SA	39" x 49' (1.5 sq.)	ASTM D6163	Fiberglass reinforced, modified bitumen membrane with 1" wide factory applied self-adhering strips on back side
Elastophene 180 Sanded	39" x 49' (1.5 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene LS FR GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene FR GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene FR+ GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene HS FR GR	39" x 33' (1 sq.)	ASTM D6162	Woven fiberglass/polyester composite reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.

Elastophene Flam GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Elastophene Flam LS FR GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Elastophene Flam FR GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Elastophene Flam FR+ GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Elastophene Flam HS FR GR	39" x 33' (1 sq.)	ASTM D6162	Woven fiberglass composite reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene 180 Sanded	39" x 33' (1 sq.) 39" x 26' (¾ sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopralene 250 Sanded	39" x 33' (1 sq.) 39" x 26' (¾ sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopralene 180 Sanded 2.2	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt or cold adhesive.
Sopralene 250 SP	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top
Soprafix-e	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a 5-inch wide side lap with a self-adhering compound and release film and sanded on the bottom and top surfaces. Applied by mechanical attachment. Lap self-adhered or sealed with approved cold adhesive.
Soprafix Base 641	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a 5-inch wide side lap with a self-adhering compound and release film and sanded on the bottom and top surfaces. Applied by mechanical attachment. Lap self-adhered or sealed with approved cold adhesive.

Sopralene 180 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Sopralene 250 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 250 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 FR+ GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 250 FR+ GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralast 50 TV Alu	various	ASTM D6298	Fiberglass reinforced modified bitumen sheeting faced with aluminum foil. Applied by heat welding of ribbon stripping (after removal of plastic burn-off film).
Soprastar Flam	39" x 33' (1 sq.)	ASTM D6162	Polyester reinforced SBS modified bitumen membrane with a plastic burn-off film on the bottom side and a reflective white top surface. Applied by heat welding.
Soprastar Stick	39" x 33' (1 sq.)	ASTM D6162	Polyester reinforced SBS modified bitumen membrane with a release film covered self-adhering bottom side and a reflective white top surface.
Sopralene Stick	39" x 33' (1 sq.)	ASTM D6164	Self-adhered, polyester reinforced membrane with a release film on the bottom and a sanded top.

Sopralene Flam Stick	39" x 33' (1 sq.)	ASTM D6164	Self-adhered, polyester reinforced membrane with a release film on the bottom and a plastic burn-off film on the top.
Elastophene Stick FR GR	39" x 33' (1 sq.)	ASTM D6163	Self-adhered, granule surfaced, fiberglass reinforced membranes.
Elastophene Stick HR FR GR	39" x 33' (1 sq.)	ASTM D6164	Self-adhered, granule surfaced, polyester reinforced membranes.
Elastocol 500	various	ASTM D41	Asphalt primer.
Elastocol Stick	various	ASTM D41	Asphalt primer.
ALSAN Flashing™	1.25 gallon pail or 3.75 gallon pail	Proprietary	One part polyurethane/bitumen resin, moisture cure compound.
ALSAN Polyfleece	4", 8" or 39" wide by 50' long	Proprietary	Non-woven polyester reinforcement used in the ALSAN Flashing system.
SBS Elastic Cement	5 gallon pail	Proprietary	Elastomeric bitumen based mastic compound.
Soprawalk	39" x 26' (3/4 sq.)	Proprietary	Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and mineral granules on the top. Applied by hot asphalt, cold adhesive or ribbon stripping.
High Velocity® Insulation Adhesive II (HVIA-II)	3 gal. pail	Proprietary	One part elastomeric urethane foam adhesive.
High Velocity® Insulation Adhesive III (HVIA-III)	4 dual cartridges per carton	Proprietary	Two part elastomeric urethane foam adhesive.
High Velocity® Insulation Adhesive III – Green	4 dual cartridges per carton	Proprietary	Two part elastomeric urethane foam adhesive.
High Velocity Insulation Adhesive PG	5 gal. Or 50 gal.	Proprietary	Two part elastomeric urethane foam adhesive.
FM Adhesive	5 gallon pail, 55 gallon drum or 350 gallon tote	Proprietary	Plastomeric bitumen based cold adhesive.
FM Adhesive (VOC)	5 gallon pail, 55 gallon drum or 350 gallon tote	Proprietary	Elastomeric bitumen based cold adhesive.
COLPLY Modified Adhesive	5 gallon pail, 55 gallon drum or 350 gallon tote	Proprietary	Elastomeric bitumen based cold adhesive.
Soprastar Adhesive	5 gallon pail or 55 gallon drum	Proprietary	SBS modified bitumen based cold adhesive.

**APPROVED INSULATIONS:****TABLE 2**

<b>Product Name</b>	<b>Product Description</b>	<b>Manufacturer (With Current NOA)</b>
ACFoam-II	Polyisocyanurate foam insulation	Atlas Roofing Corporation
Sopra-ISO s	Polyisocyanurate foam insulation	Soprema, Inc.
Sopra-ISO r	Polyisocyanurate foam insulation	Soprema, Inc.
M-Shield	Polyisocyanurate foam insulation	Soprema, Inc.
Sopraboard	Mineral fortified asphaltic cored coverboard	Soprema, Inc.
DensDeck	Water resistant gypsum board	Georgia Pacific Gypsum LLC
H-Shield	Polyisocyanurate foam insulation	Hunter Panels LLC
ENRGY 3	Polyisocyanurate foam insulation	Johns Manville Corp.
Multi-Max FA-3	Polyisocyanurate foam insulation	RMax Operating, LLC
High Density Wood Fiberboard	Wood fiber insulation board	Generic

**APPROVED FASTENERS:****TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
1.	Twin Loc-Nails	Base ply fastening systems for lightweight concrete, gypsum or cementitious wood fiber decks.	Various	ES Products, Inc.
2.	ES Products Batten Bar	Batten bar.		ES Products, Inc.
3.	Polymer Batten Bar	Modified polymer batten bar.		OMG, Inc.
4.	Polymer GypTec	Glass reinforced nylon fastener.	Various	OMG, Inc.
5.	Polymer GypTec Insulation Plate	Galvalume plate.	3" round	OMG, Inc.
6.	Dekfast Coiled Batten Strip	Batten bar.		SFS Intec
7.	Soprafix MBB-R	Batten bar.		Soprema, Inc.
8.	Tru-Fast Twin-Loc Batten Bar	Batten bar.		Altenloh, Brinck & Co. U.S., Inc.

## APPROVED SURFACING/COATING OPTIONS:

TABLE 4

Chosen components must be applied according to manufacturer's application instructions. Any coating, listed below, used as a surfacing, must be listed within a current NOA.

System Number	Manufacturer	Application
1.	Generic	Gravel applied at 400 lbs./sq., adhered with flood coat of asphalt at 60 lbs./sq.
2.	Generic	Slag applied at 300 lbs./sq., adhered with flood coat of asphalt at 60 lbs./sq.
3.	Soprema, Inc.	Gravel applied at 400 lbs./sq., adhered with FM Adhesive, FM Adhesive (VOC), COLPLY Modified Adhesive or Soprapstar Adhesive at 4 gal./sq.
4.	Karnak Corporation	Karnak #97 Fibrated Aluminum Roof Coating applied at an application rate of 1.5 gal./sq.
5.	Soprema, Inc.	Cural Aluminizer applied at an application rate of 2 gal./sq.
6.	Thermo Manufacturing Systems, LLC	Super Prep Roof Coating applied in two coats at an application rate of 1.5 gal./sq./coat.
7.	United Coatings Manufacturing Company	Roof Mate Coating, applied in one base coat at a rate of 1.5 gal./sq. and one finish coat at a rate of 1.5 gal./sq.
8.	Insulating Coatings Corporation	Astec 2000 Finish Coat applied in two base coats at a rate of 0.75 gal./sq./coat and two finish coats at a rate of 0.75 gal./sq./coat.
9.	Henry Company	HE280DC White Elastomeric Roof Coating applied in two coats at an application rate of 1 gal./sq./coat.
10.	National Coating Corp.	Acryshield® A500 applied in two coats at an application rate of 1 gal./sq./coat.
11.	Soprema, Inc.	R-Nova Roof Coating
12.	Generic	Semi-ceramic coated colored granules.



**EVIDENCE SUBMITTED:**

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	3002351	FM 4470	02/28/03
	3023749	FM 4470	09/28/06
	3029098	FM 4470	10/25/07
	3045101	FM 4470	11/05/12
Underwriters Laboratories	R11436	UL 790	06/18/13
Exterior Research & Design, LLC.	2757.02.05	ASTM D6163/D6164	02/03/05
	2766.12.03	TAS 114	12/01/03
	2764.09.03	TAS 114	09/16/03
Trinity   ERD	S6740.11.07	ASTM D 6163	11/02/07
	S12370.03.09-1	ASTM D 6164	03/06/09
	S12370.03.09-2	ASTM D 6164	03/06/09
	S12370.03.09-3	ASTM D 6162	03/06/09
	S11440.06.10	ASTM D4798 & TAS 110	06/01/10
	S11440.01.11-R1	ASTM D6164	06/07/12
	S11440.11.10-4	ASTM D2178	11/17/10
	S11440.11.10-3-R1	ASTM D4601	01/30/13
	S11440.12.10-1-R1	ASTM D6163	06/07/12
	S32700.12.10	ASTM D6162	12/15/10
	S35860.12.11-1	ASTM D2178	12/12/11
	S35860.12.11-2	ASTM D4601	12/12/11
	S35860.05.12-1-R1	ASTM D6163	06/07/12
	S35860.05.12-2-R1	ASTM D6164	06/07/12
	S35860.05.12-3	ASTM D6164	05/08/12
PRI Construction Materials Technologies, LLC	SOP-049-02-01	ASTM D1644/D2196	05/31/12
	SOP-043-02-01	ASTM D4601	02/27/12
	SOP-042-02-01	ASTM D4601	02/27/12
	SOP-041-02-01	ASTM D2178	02/27/12
	SOP-040-02-01	ASTM D2178	02/27/12
	SOP-010-02-01.03	TAS-138	07/26/11
	SOP-050-02-01	ASTM D3019	07/12/12





## APPROVED ASSEMBLIES:

**Membrane:** SBS

**Deck Type 5I:** Cementitious Wood Fiber, Insulated

**Deck Description:** Cementitious Wood Fiber

**System Type A:** Anchor sheet mechanically fastened, all layers of insulation adhered with approved asphalt or adhesive.

### All General and System Limitations apply.

**Anchor Sheet:** One layer Soprabase, Soprabase S, Elastophene 180 Sanded, Sopralene 180 Sanded, Sopralene 180 Sanded 2.2, Sopralene 250 Sanded, Sopralene 250 SP, mechanically attached with 1.8" long Twin Loc-Nails spaced 6" o.c. in min. 4" lap and 6" o.c. in two evenly spaced, staggered rows in the field.

One or more layers of the following.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s, ENRGY 3, Multi-Max FA-3, Sopra-ISO r, M-Shield or H-Shield Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck Minimum ¼" thick</b>	N/A	N/A
<b>Sopraboard Minimum 1/8" thick</b>	N/A	N/A
<b>Approved High Density Wood Fiberboard Minimum 1/2" thick</b>	N/A	N/A

**Note:** All insulation shall be adhered to the vapor barrier in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs./100 ft<sup>2</sup>, or in Soprema High Velocity<sup>®</sup> Insulation Adhesive II (HVIA-II), High Velocity<sup>®</sup> Insulation Adhesive III (HVIA-III), High Velocity<sup>®</sup> Insulation Adhesive III –Green or High Velocity<sup>®</sup> Insulation Adhesive PG adhesive in ¾" wide ribbons spaced 6" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as a final membrane substrate.

**Primer:** Top insulation layer primed with Elastocol Stick at a rate of 1 gal./sq.

**Base Sheet:** One layer Colvent SA self-adhered.

**Ply Sheet:** None.

**Membrane:** One layer of Soprastar Stick self-adhered to sand surfaced base or ply membrane primed with Elastocol Stick.  
Or  
One layer of Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Elastophene Flam HS FR GR, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR+ GR, Soprastar Flam, Sopralast 50 TV Alu, heat welded.

**Membrane:** Or  
**(Cont.)** One layer of Elastophene GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR+ GR, Elastophene HS FR GR, Sopralene 180 FR GR, Sopralene 250 FR GR, adhered in hot asphalt at 25 lbs./sq. or applied in FM Adhesive. FM Adhesive (VOC). COLPLY Modified Adhesive or Soprastar Adhesive at a rate of 1.5 gal./sq.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

**Maximum Design Pressure:** -60 psf. (See General Limitation #7.)

**Membrane:** SBS

**Deck Type 5I:** Insulated Cementitious Wood Fiber Decks

**Deck Description:** Cementitious Wood Fiber

**System Type C:** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** FM approved Self-Adhering, Cold-Applied, Hot-Applied or Torch-Applied base sheets.

**(Optional)**

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
H-Shield, Sopra-ISO r, M-Shield, ACFoam- II, Sopra-ISO s, ENRGY 3, Multi-Max FA-3 Minimum 1.4" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
DensDeck Minimum ¼" thick	4 with 5	1: 2 ft <sup>2</sup>

**Note:** All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Refer to Roofing Application Standard RAS 117 for insulation attachment.

**Primer:** Top Insulation layer shall be primed with ASTM D41 asphaltic primer or Elastocol Stick applied at a rate of 1 gal./sq., to deck.

**Base Sheet:** One layer of Sopralene Stick or Sopralene Flam Stick\*, self-adhered  
\*Requires heat welded ply or cap sheet.

**Ply Sheet:** None

**Membrane:** One layer of Soprastar Stick self-adhered to sand surfaced base or ply membrane primed with Elastocol Stick.

Or

One layer of Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Elastophene Flam HS FR GR, Soprastar Flam, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, heat welded

Or

One layer of Elastophene GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR+ GR, Elastophene HS FR GR, Sopralene 180 FR GR, Sopralene 250 FR GR, adhered in hot asphalt at 25 lbs./sq. or applied in FM Adhesive, FM Adhesive (VOC), COLPLY Modified Adhesive or Soprastar Adhesive at a rate of 1.5 gal./sq. to sand surfaced base or ply membrane.

**Surfacing:**

Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design  
Pressure:**

-45 psf. (See General Limitation #9.)

**Membrane:** SBS

**Deck Type 5I:** Cementitious Wood Fiber, Insulated

**Deck Description:** Cementitious Wood Fiber

**System Type D:** All layers of insulation and base sheet simultaneously attached.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any approved PolyIso insulation board listed in Table 2</b>		
<b>Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any approved coverboard board listed in Table 2</b>		
<b>Minimum 1/4" thick</b>	1	See Note Below

**Note:** Top insulation layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Layer:** One layer Soprafix-e or Soprafix Base 641, mechanically attached with Twin-Loc Nails spaced 6" o.c. through Polymer Batten Bar, ES Products Batten Bar, Tru-Fast Twin Loc Batten Bar or Dekfast Coiled Batten Strip, Soprafix MBB-R placed in the 5" wide self-adhered lap and in one row centered in the field. Center fastener row is covered with an 8" wide strip of Sopralene Stick, self-adhered.

**Ply Sheet:** None.

**Membrane:** One layer of Soprapstar Stick, Elastophene Stick HR FR GR, Elastophene Stick FR GR, self-adhered to sand surfaced base or ply membrane primed with Elastocol 500, Elastocol Stick.

Or

One layer of Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Elastophene Flam HS FR GR, Soprapstar Flam, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, heat welded.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

**Maximum Design Pressure:** -45 psf. (See General Limitation #7)



## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.  
**Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**

